

Ultrasonic sensor UC500-D1-3K-V7




Features

- Specially for level monitoring in vessels
- Large operating voltage range
10 V DC ... 252 V DC
20 V AC ... 252 V AC
- 3 relay outputs
- Parameter assignment via DIP-switches
- Temperature compensation

Electrical connection


Standard symbol/Connection:



Connector V7



Dimensions



Technical data



General specifications

Sensing range	60 ... 550 mm
Unusable area	0 ... 60 mm
Standard target plate	100 mm x 100 mm
Transducer frequency	approx. 380 kHz
Response delay	> 10 s, relay < 1 s, LEDs

Indicators/operating means

LED red	LED 1: overflow indication LED 4: underfill indication
LED green/yellow	LED 2: overflow warning and normal operation LED 3: normal operation and underfill warning setting of the switch points/operating modes

DIP-switch

Electrical specifications

Operating voltage	10 ... 252 V DC 20 ... 252 V AC, 47 ... 63 Hz
No-load supply current I_0	< 30 mA with $U_B = 30$ V DC < 110 mA at $U_B = 10$ V DC < 25 mA at $U_B = 220$ V AC

Output

Output type	3 relay outputs, normally open/closed, selectable
Range hysteresis H	20 mm
Contact loading	252 V AC/150V DC, 3 A (ohm. load)
Lifetime	Electrical: 10^5 switching cycles at resistive load (3 A / 252 V AC or 3 A / 30 V DC) min. contact load: 100 μ A / 100 mV DC mechanical: 20×10^6 switching cycles

Temperature influence

Standard conformity

Standards	EN 60947-5-2
-----------	--------------

Ambient conditions

Ambient temperature	-20 ... 60 °C (253 ... 333 K)
Storage temperature	-40 ... 85 °C (233 ... 358 K)

Mechanical specifications

Protection degree	IP65
Connection	Cable connector 90° V7, (7-pin)

Material


Housing	cover: PC housing: PBT threaded flange: stainless steel installation connector/cable socket: PETP epoxy resin/hollow glass sphere mixture; polyurethane foam
Transducer	700 g

Notes

Safety notes:

The supply circuit is separated from the relay circuit by basic insulation.

The cover may only be opened by specially trained personnel. Degree of contamination 2 is permissible when the cover is open. Ensure that the sealing ring of the cover is in good condition.



Safety class II is only guaranteed when using the accessory cable box and the associated mounting screw with plastic head. When operating this device with operating voltage exceeding 42 V, you must replace the metal mounting screw by the supplied plastic head mounting screw to avoid electric treatment. The cable box may only be separated from the unit when the power is off.

CAUTION:

The UC500-D1-K3-V7 ultrasonic sensor is **not** suitable for use in environments subject to explosion hazards.

Conformity: EN 60947-5-2
 Housing insulation: Safety class II
 Degree of contamination: 4
 Overvoltage category: III

TEACH-IN of switching points:

One switching point can be taught for each of the 3 switch outputs. Set DIP switch 5 to ON to put the sensor in TEACH-IN mode. The sensor indicates TEACH-IN mode with two lit red LEDs. The green-yellow LEDs are off.

Next, position a suitable target object at the desired switching point in front of the sensor and switch the DIP switch associated with the relevant switch output (switches 1-3). The sensor will now be flashing yellow or green in addition to the lit red LEDs. Flashing green indicates that the target object was detected; flashing yellow signals that it was not detected. The measured switching point will be transferred to RAM when the associated DIP switch is switched back while the LED is flashing green. Only the red LEDs should now be lit. This signals the user that the DIP switches 1-3 have been restored to their original positions. The other switching points are set in the same manner. The TEACH-IN procedure is completed by setting DIP switch 5 back to the OFF position. The measured switching points will then be transferred to the nonvolatile EEPROM.

Under normal circumstances, switching point A1 should be less than A2, and A2 less than A3. If this is not observed, the sensor will automatically exchange the switching points after the TEACH-IN procedure is complete so that $A1 < A2 < A3$. This ensures that the LEDs respond correctly and that the shortest switching point is assigned to relay 1, the middle distance to relay 2 and the longest distance to relay 3.


If DIP switch 4 is switched during TEACH-IN, the default value for the switching point will be set rather than a target object. The default values for the switching points are 60 mm for A1, 220 mm for A2 and 270 mm for A3.

Model number

UC500-D1-3K-V7

Characteristic curves/additional information


Characteristic response curves



Curve 1: flat surface 100 mm x 100 mm
 Curve 2: round bar, Ø 25 mm

Indicators/operating means

LED	S4 = OFF	S4 = ON
1 ⊗ (red)	full	full
2 ⊗ (green/yellow)	high	normal
3 ⊗ (green/yellow)	normal	low
4 ⊗ (red)	empty	empty



Accessories

Connector

V7-W

Display during TEACH-IN:

DIP1-3	one or more DIP switches changed TEACH-IN active			in normal state TEACH-IN complete	
DIP4	normal state TEACH-IN of object distance		changed default parameter	normal state	changed
State	object detected	object not detected	default active		
LED 1, red	lit	lit	lit	lit	lit
LED 2, green/yellow	flashes green	off	lit green	off	lit green
LED 3, green/yellow	off	flashes yellow	lit yellow	off	lit yellow
LED 4, red	lit	lit	lit	lit	lit

The relays switch to the "safe state" (all relays open, regardless of close/open function) during TEACH-IN.

Setting the switching behaviour:

In normal mode (DIP switch 5 OFF), the DIP switches 1 to 3 can be used to set the switching behaviour of the switch outputs 1 to 3. If the associated DIP switch is ON, the associated switch output has a close function; if the switch is set to OFF the output has an open function. Close function means that the relay trips when the object distance is less than the associated switching point; in the case of open function, the relay trips when the object distance is greater than the switching point. The relays switch to the "safe state" (all relays open, regardless of close/open function) in the event of a failure

Setting the display modes:

Two display modes can be selected with DIP switch 4:

Display mode 1: DIP switch 4 ON, underfill warning:

Object distance x	$x < A1$	$A1 < x < A2$	$A2 < x < A3$	$x > A3$
LED 1, red (full)	flashes	off	off	off
LED 2, green/yellow (normal)	off	lit green	off	off
LED 3, green/yellow (low)	off	off	flashes yellow	off
LED 4, red (empty)	off	off	off	flashes

In this mode LED 1 (red) serves as the overfilling indicator, LED 2 (green) indicates the normal state, LED 3 (yellow) serves as the preliminary warning that the container is nearly empty and LED 4 (red) signals the "container empty" state.

Display mode 2: DIP switch 4 OFF, overfill warning

Object distance x	$x < A1$	$A1 < x < A2$	$A2 < x < A3$	$x > A3$
LED 1, red (full)	flashes	off	off	off
LED 2, green/yellow (high)	off	flashes yellow	off	off
LED 3, green/yellow (normal)	off	off	lit green	off
LED 4, red (empty)	off	off	off	flashes

In this mode LED 1 (red) serves as the overfilling indicator, LED 2 (yellow) serves as the preliminary warning that the container is nearly full, LED 3 (green) indicates the normal state, and LED 4 (red) signals the "container empty" state.

The relays switch to the "safe state" (all relays open, regardless of close/open function) in the event of a failure.